

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 03/Certificate/2025-26.

Dated: 26.05.2025

It is certified that an inspection team headed by ...ANIL KUMAR (Assistant Research Officer)

(Name of Officers with designation) from ...U.P. Jal Nigam (Rural PHED) Lucknow.

inspected the ...Study Hall School, Pipersand, Sarojini Nagar, Lucknow

(Name & Address of the school) on 26.05.2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. ...141927/2025-26 dated ...22.05.2025

of ...State Lab U.P. Jal Nigam (PHED Lab) certified that the

...Study Hall School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till ...25-05-2026

Signature with Seal: 

Name : ...ANIL KUMAR

Designation : ...ASSISTANT RESEARCH OFFICER

Name & Address of the Office / Department : ...

To Principal

...Study Hall, School, Pipersand, Lucknow
(Name & Address of the Institution)

(Anil Kumar)
Assistant Research Officer
U.P. Jal Nigam (Rural)
Lucknow

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Analysis Report

State Level Water Analysis Laboratory, U.P. Jal Nigam (Rural)
6, Rana Pratap Marg, Lucknow.



Certificate No.: TC-13060

Report No	Chemical Test/141927/2025-26	Date	22.05.2025	S.No		Page No	1	page 1/1
-----------	------------------------------	------	------------	------	--	---------	---	----------

Customer Details

Office Name and Address	Study Hall School, Piparsand, Sarojini Nagar, Lucknow.
Ref Letter No & Date	19.05.2025

Basic details of sample

District	Lucknow	Block/Area	Sarojini Nagar
Gram Panchayat	Piparsand	Village/Ward	Piparsand
Habitation		Location	Piparsand
Water Source	RO Water	Sample No.	141927
Quantity of Sample	1000ml	Date of S.C.	19.05.2025
Receiving Date	19.05.2025	S. Collector	By the Customer :- Shri Pratayush Shukla
Sample Depositer	Shri Pratayush Shukla	Analysis Completion Date	20.05.2025
Analysis Start Date	20.05.2025		


Environmental Condition

Temperature	22± 5 °C	Relative Humidity	Upto 70%
-------------	----------	-------------------	----------

Technical Data of Analysis

S.No.	Analysed parameters	Unit of Measurement	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit in absence of alternate source	
1	2	3	4	5	6	7
1	pH	-	8.48	6.5-8.5	6.5-8.5	IS 3025 (Part II) :2012 (RA :2022)
2	Turbidity	NTU	2.62	1.00	5.00	IS 3025 (Part 10) : 2023
3	TDS	mg/L	112	500	2000	IS 3025 (Part 16) : 2023
4	Chloride	mg/L	9.85	250	1000	IS 3025 (Part 32) : 2014 (RA: 2019)
5	Total Alkalinity	mg/L	10	200	600	IS 3025 (Part 23) : 2023
6	Total Hardness	mg/L	70	200	600	IS 3025 (Part 21) : 2009 (RA: 2019)
7	Sulphate	mg/L	2.0	200	400	IS 3025 (Part 24) : 2009 (RA: 2022)
8	Fluoride	mg/L	0.10	1.00	1.50	IS 3025 (Part 60) : 2008 (RA: 2019)
9	Nitrate	mg/L	1.20	45	45	APHA 24 th Edition 2023, Meth, 4500 No ₃ -B

- Note
1. This Certificate refers only to the particular sample(s) submitted for testing.
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 4. Sample will be stored up to 15 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.


22/05/2025
(Abhishek Singh)
Lab Technician
Prepared By

Authorized Signatory

Technical Manager
(Abhishek Singh)

**End of Test Report **

Laboratory Contact details-Email-upjnlabtesing@gmail.com, Mob-9473942098



Analysis Report

State Level Water Analysis Laboratory, U.P. Jal Nigam (Rural)
6, Rana Pratap Marg, Lucknow.



Certificate No.: TC-13060

Report No Biological Test/141927/2025-26 Date 22.05.2025 S.No Page No 1 page 1/1

Customer Details

Office Name and Address Study Hall School, Piparsand, Sarojini Nagar, Lucknow.
Ref Letter No & Date 19.05.2025

Basic details of sample

District Lucknow Block/Area Sarojini Nagar
Gram Panchayat Piparsand Village/Ward Piparsand
Habitation Location Piparsand
Water Source RO Water Sample No. 141927
Quantity of Sample 250ml Date of S.C. 19.05.2025
Receiving Date 19.05.2025 S. Collector By the Customer :- Shri Pratayush Shukla
Sample Depositer Shri Pratayush Shukla
Analysis Start Date 20.05.2025 Analysis Completion Date 20.05.2025

Environmental Condition


Temperature $22 \pm 5^{\circ}\text{C}$ Relative Humidity Upto 70%

Technical Data of Analysis

S.No.	Analysed parameters	Unit of Measurement	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit in absence of alternate source	
1	2	3	4	5	6	7
1	Total Coliform	CFU/100 mL	0.00	Shall not be detectable in any 100ml Sample	Shall not be detectable in any 100ml Sample	IS 15185 : 2016 (RA: 2021)
2	E.coli	CFU/100 mL	0.00	Shall not be detectable in any 100ml Sample	Shall not be detectable in any 100ml Sample	IS 15185 : 2016 (RA: 2021)

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 15 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.


22/05/2025
(Abhishek Singh)
Lab Technician
Prepared By


Authorized Signatory
Technical Manager
(Anil Kumar)
Technical Manager

**End of Test Report **

Laboratory Contact details-Email-upjnlabtesing@gmail.com, Mob-9473942098