

Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 0/150024/26-27

Dated: 29.05.2026

It is certified that an inspection team headed by Anil Kumar (Assistant Research Officer)

U.P. Jal Nigam (Rural) Lucknow (Name of Officers with designation)

from State Level Water Analysis Laboratory, Lucknow. PHED

inspected the Study Hall School, Piparsand, Sarojini Nagar, Lucknow

(Name & Address of the school) on 24.05.2026 (date of inspection) and on the basis

of Water Test Report (Attached) bearing no. Chemical Test, Bact./150024/26-27

dated 29.05.2026 of State Lab UP Jal Nigam (PHED Lab)

certified that the

Study Hall School. (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains

the hygienic sanitation condition in the school building & the campus as per norms

prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 28.05.2027

Signature with Seal: 

Name : (Anil Kumar)

Designation : Assistant Research Officer

Name & Address of the Office / Department : U.P. Jal Nigam (Rural)

Lucknow

To Principal

Study Hall School, Piparsand, Lucknow.

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Analysis Report

State Level Water Analysis Laboratory, U.P. Jal Nigam (Rural)
6, Rana Pratap Marg, Lucknow.



TC-13060

Report No Chemical Test/150024/2026-2027 Date 29.05.2026 S.No1 Page No 1 page 1/1

Customer Details

Office Name and Address Study Hall School, Piparsad, Kanpur road, Sarojaninagar, Lucknow.
Ref Letter No & Date 21.05.2026

Basic details of sample

District Lucknow Block/Area Sarojaninagar
Gram Panchayat - Village/Ward Piparsad
Habitation - Location Post sarojani nagar, Thana sarojaninagar
Water Source RO Sample No. 150024
Quantity of Sample 1000ml +500ml Date of S.C. 21.05.2026
Receiving Date 21.05.2026 S. Collector By the Customer:- Shri Pratyush Shukla
Sample Depositer Shri Pratyush Shukla
Analysis Start Date 21.05.2026 Analysis Completion Date 21.05.2026

Environmental Condition


Temperature 22± 5 °C Relative Humidity Upto 70%

Technical Data of Analysis


S.No.	Analysed parameters	Unit of Measurement	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit In absence of alternate source	
1	2	3	4	5	6	7
1	pH	-	7.5	6.5-8.5	No Relaxation	IS 3025 (Part II) :2012 (RA :2022)
2	TDS	mg/L	120	500	2000	IS 3025 (Part 16) : 2020
3	Turbidity	NTU	1.00	1.00	5.00	IS 3025 (Part 10) : 2023
4	Chloride	mg/L	7.39	250	1000	IS 3025 (Part 32) : 2014 (RA: 2019)
5	Total Hardness	mg/L	15	200	600	IS 3025 (Part 21) : 2009 (RA: 2019)
6	Total Alkalinity	mg/L	70	200	600	IS 3025 (Part 23) : 2008
7	Sulphate	mg/L	1.20	200	400	IS 3025 (Part 24) : 2009 (RA: 2022)
8	Nitrate	mg/L	1.89	45	No Relaxation	APHA 24 th Edition 2023, Meth, 4500 NO ₃ -B
9	Fluoride	mg/L	0.51	1.00	1.50	IS 3025 (Part 60) : 2008 (RA: 2019)
10	Iron	mg/L	0.102	1.00	1.00	APHA 24rd edition, 2023 (Part 3125) ICP-MS Method
11	Arsenic	mg/L	0.001	0.01	0.01	APHA 24rd edition, 2023 (Part 3125) ICP-MS Method
12	Magnesium	mg/L	10.95	30	100	APHA 24th Edition, 2023 (Part 3125) ICP-MS Method
13	Calcium	mg/L	10.00	75	200	APHA 24th Edition, 2023 (Part 3125) ICP-MS Method

BDL refers to Below Detection Limit.

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 15 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.
5. BDL - Below Detection Level


(Kamini Singh)
Lab Technician
Prepared By

Authorized Signatory


Anil Kumar
Technical Manager


**End of Test Report **

Laboratory Contact details-Email-upjnlabtesting@gmail.com, Mob-9473942098



Analysis Report

State Level Water Analysis Laboratory, U.P. Jal Nigam (Rural)
6, Rana Pratap Marg, Lucknow.



TC-13060

Report No	Bacteriological Test/150024/2026-2027	Date	29.05.2026	S.No	Page No	1	page 1/1
-----------	---------------------------------------	------	------------	------	---------	---	----------

Customer Details

Office Name and Address	Study Hall School ,Piparsad, Kanpur road, Sarojaninagar, Lucknow.
Ref Letter No & Date	21.05.2026

Basic details of sample

District	Lucknow	Block/Area	Sarojaninagar
Gram Panchayat		Village/Ward	Piparsad
Habitation		Location	Post sarojani nagar, Thana sarojaninagar
Water Source	RO	Sample No.	150024
Quantity of Sample	250 ml	Date of S.C.	21.05.2026
Receiving Date	21.05.2026	S. Collector	By the Customer:- Shri Pratyush Shukla
Sample Depositer	Shri Pratyush Shukla		
Analysis Start Date	21.05.2026	Analysis Completion Date	22.05.2026


5

Temperature	22± 5 °C	Relative Humidity	Upto 70%
-------------	----------	-------------------	----------

Technical Data of Analysis

S.No.	Analysed parameters	Unit of Measurement	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit in absence of alternate source	
1	2	3	4	5	6	7
1	Total Coliform	CFU/100 mL	0.00	Shall not be detectable in any 100ml Sample	Shall not be detectable in any 100ml Sample	IS 15185 : 2016 (RA: 2021)
2	E.coli	CFU/100 mL	0.00	Shall not be detectable in any 100ml Sample	Shall not be detectable in any 100ml Sample	IS 15185 : 2016 (RA: 2021)

- Note
1. This Certificate refers only to the particular sample(s) submitted for testing.
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 4. Sample will be stored up to 15 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.
 5. BDL - Below Detection Level


(Kamini Singh)
Lab Technician
Prepared By

Authorized Signatory


(Anil Kumar)
Technical Manager

**End of Test Report **

Laboratory Contact details-Email-upjnlabtesting@gmail.com, Mob-9473942098

